

Status	Contaminant	Results	Units	National Standards	Min. Detection Level
Microbiologicals					
✓	Iron Bacteria by P/A	Iron Related Bacteria is ABSENT in this Sample.			
Inorganic Analytes - Metals					
●	Calcium	23.7	mg/L	--	2.0
●	Copper	0.009	mg/L	1.3	EPA Action Level 0.004
▲	Iron	29.331	mg/L	0.3	EPA Secondary 0.020
●	Iron-Dissolved	28.748	mg/L	--	0.020
●	Magnesium	27.93	mg/L	--	0.10
▲	Manganese	0.684	mg/L	0.05	EPA Secondary 0.004
●	Potassium	7.0	mg/L	--	1.0
●	Silica	15.1	mg/L	--	0.1
●	Sodium	40	mg/L	--	1
Physical Factors					
✓	Alkalinity (Total as CaCO3)	ND	mg/L	--	20
✓	Corrosivity	-4.451	SI	--	
▲	Hardness	170	mg/L	100	NTL Internal 10
▲	pH	5.6	pH Units	6.5 to 8.5	EPA Secondary
●	Total Dissolved Solids	190	mg/L	500	EPA Secondary 20
▲	Turbidity	150.0	NTU	1.0	EPA Action Level 0.1
Inorganic Analytes - Other					
✓	Nitrate as N	ND	mg/L	10	EPA Primary 0.5
✓	Nitrite as N	ND	mg/L	1	EPA Primary 0.5
●	Sulfate	15.0	mg/L	250	EPA Secondary 5.0
●	Tannin/Lignin	16.0	mg/L	--	0.5

*We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the U.S. Environmental Protection Agency or variations of these EPA methods.*

*These test results are intended to be used for informational purposes only and may not be used for regulatory compliance.*

***National Testing Laboratories, Ltd.***

NATIONAL TESTING LABORATORIES, LTD